

From Director General
Fire Service, Haryana Panchkula

To M/s Siya Openmind LLP
Sector 67, Gurugram

Memo No. FS/2023/1004 dated : 20/10/2023

Subject : Fire Safety Certificate Under 15 mtrs. from the fire safety point of view for **Group B-Educational Building at High School HS 2 meas. 5.00 acres Block H of falling in Residential plotted colony namely Esencia at Sector 67, Gurugram of M/s Siya Openmind LLP :**

Reference your letter no. 050262323002667 dated 26/08/2023 on the subject cited above

Tower Name	Floor Detail	Height	Ground Coverage
Block- A	G+01	7.50 Mt	2236.8686 Sq. Mt (Part)

Basement Level	Basement Area	Basement Remarks
Basement- 01	2236.8686 Sq. Mt.	Block- A

- 1) All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- 2) The open set back area is not checked at our end as it shall be checked by concerned building authority/department
- 3) If any lapse or non functioning of fire system will be the sole responsibility of the owner/occupier.
- 4) All the means of escape shall be kept free of all the type of obstruction all the time.
- 5) All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 6) Fire Safety Certificate granted subject to condition that there is no violation in sanctioned building plan by virtue of which fire fighting scheme was approved.
- 7) This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any
- 8) The owner/occupier shall strictly follow the other applicable rules/by laws laid down regarding fire safety system. If you fail to comply with any of the above terms & conditions, This fire NOC will be deemed cancelled and you will be liable to be punish as per Section 30,31 & 47 of Fire & Emergency Services Act- 2022.
- 9) If the infringements of Byelaws remains un- noticed the Authority reserves the right to amend the Fire Safety Certificate as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 10) The owner or occupier of the building shall give a self-declaration certificate annually to the effect that the fire fighting system installed in his building is working in good condition and there is no addition/alteration in the building. The Fire Officer may randomly check such building. In case there is any addition/alteration beyond permissible limits under the Haryana Building Code, 2017, the fire safety certificate shall cease to exist and the owner shall apply for approval of revised Fire Fighting Scheme as per the provisions of section 18

The above Fire Safety Certificate is valid for only **Three** year from the date of issue of this letter Applying renewal of the same well in time shall be the responsibility of owner/occupier.

Remarks:- Part Fire Safety Certificate for part area of Block A



Deputy Director (Technical)-I,
for Director General, Fire
Service, Haryana
Panchkula

Exercising the power of Director Fire Services, Haryana

DELHI PUBLIC SCHOOL
(A Unit of JSR Sanskriti Foundation)
Sector-67A, Gurugram

Sdhanu
Authorized Signatory

For JSR SANSKRITI FOUNDATION
A.P
Authorised Signatory



Digitally signed by GULSHAN
KALRA
Date: 2023.10.20 11:44:37 +05:30
Reason: Digital Verification

Office of Fire Station Sector-29, Gurugram
To Whom It May concern

Memo No-FSG/2024/3483

Date- 19-12-2024

It is stated that Fire Safety Certificate issued by this office in the name of Siya Openmind LLP vide letter no-FS/2023/1004 Dated- 20/10/2023 which was valid for three years from the date of issuance.


Now Delhi Public School (Land Owner Siya Openmind LLP) has requested that name of school running in the name Delhi Public School (Land Owner Siya Openmind LLP) may be added due to CBSE affiliation requirement.

So this office has no objection from giving Fire Safety Certificate letter for CBSE affiliation in the name of Delhi Public School (Land Owner Siya Openmind LLP), Sector-67, Gurugram.

This letter should not be used in any other purpose. This is for information only.

DELHI PUBLIC SCHOOL
(A Unit of JSR Sanskriti Foundation)
Sector-67A, Gurugram


Authorized Signatory


Deputy Director (Tech),
Fire & Emergency Services, (Tech)
Gurugram. Fire Station, Gurugram

For JSR SANSKRITI FOUNDATION


Authorized Signatory