

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE.

No. S.H./2025/ 115

Date :

12/06/2025

It is certified that an inspection team headed by Dr. Rashmi Batra, Dy. Civil Surgeon, Gurugram and inspection done by Dr Amit Ahuja Nodel Officer , School health, Gurugram of Delhi Public School, Sector-67 A ,GURUGRAM , ON DATED 03/06/2025. They Checked the Water test report Submitted by School and found that the School has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

This Certificate is valid for a period of One Year.

Signature with Seal:

Rashmi
CIVIL SURGEON
GURUGRAM
Rashmi

Name:

Designation:

To,

Delhi Public School,

Sector-67 A,

GURUGRAM.

(Name & Address of the Institution)

DELHI PUBLIC SCHOOL
(A Unit of JSR Sanskriti Foundation)
Sector-67A, Gurugram

Rashmi
Authorized Signatory

DELHI PUBLIC SCHOOL
(A Unit of JSR Sanskriti Foundation)
Sector-67A, Gurugram

A. T. P.
Authorized Signatory

DISTRICT PUBLIC HEALTH LAB

DISTRICT CIVIL HOSPITAL, GURUGRAM

D.No. 129/2025/Micro

To Dated 5/6/2025

The S.M.O./M.O. Incharge,

CHC/PHC CS Gurugram

SUB : WATER SAMPLES REPORT

In reference to your letter No. CS/HP/33
Dated 3/6/2025

..... vide which you have sent water samples for bacteriological examination, the result of each is as under:

Sr. No. Place of Collection

Sr. No.	Place of Collection	Result	PCC
1.	Our Montessori House Play School, Sec 48, Ggm	FIT	0/100ml class I
2.	Bellu Public School, Sec 67A, Gurugram	FIT	2/100ml class II
3.	Vidya Vana School, DLF Ph-2, Gurugram	FIT	0/100ml class I
4.	Vikas Model School, Gandhi Nagar	FIT	0/100ml class I
5.	HSM Model Convent School, Gurawali Enclave	FIT	0/100ml class II

P.C.C. Presumptive coliforms count

Above samples are tested by multiple tube methods.

INTERPRETATION

PCC Per 100ml	CLASS	REMARK	RESULT
0	I	EXCELLENT	FIT
1-3	II	SATISFACTORY	FIT
4-9	III	SUSPICIOUS	UNFIT
> 9	IV	UN SATISFACTORY	UNFIT

The Result given above are related to samples as received & tested in Lab..

DELHI PUBLIC SCHOOL
(A Unit of JSR Sanskriti Foundation)
Sector-67A, Gurugram

J. Sharma
Authorized Signatory

Dr. Manisha Rajan
MBBS, MD-Microbiology
Medical Officer 6/1
Civil Hospital, Gurugram
MCI - 11-40072

Skjord
H.S
6-6-25

DELHI PUBLIC SCHOOL
(A Unit of JSR Sanskriti Foundation)
Sector-67A, Gurugram

A. T. P
Authorized Signatory